

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1517:120 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Commercial Products Group, 1130 Milepost Dr., Columbus, OH 43228
Contact: Andrew Keller (309) 762-0731

DESIGN: Model V1971, Series DA1, JA1, MA1 and WA1 strobe lights with clear lens and Model VSYNC synchronizable module. Refer to listee's data sheet for additional product description and operational considerations. Model V1971 may also be mounted on Commercial Products Group listed horns and speakers as follows:

450E, -460	Electric Horn
MPV	Mounting plate
450D	Horn
ASLP, ASHP	Amplified speakers
MSHP, MSLP, MSDP, SPA, SPL, SPHP	Speakers

RATING: Candela: DA1: 15/75 cd, JA1: 30/75 cd, MA1: 75 cd, WA1: 110 cd.
Electrical: 16-33 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes, ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application (with clear lens only). Intended for use on wall in non-sleeping areas or in sleeping areas provided the lens top is located at or below 24 inches from the ceiling. For indoor use only or *indoor/outdoor use with Model VW kit. Not intended for use on a ceiling. Refer to listee's Installation Instruction Manual for details..

*Rev. 5-01-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager